



MARC Northeast Maintenance Facility: Lighting FAQ

LIGHTING

What sort of lighting shall be used for the site?

Low mast, pole mounted, LED fixtures with shielding are proposed for the site. The design goal is to utilize low mast LED fixtures for the entire site.

Will the buildings be equipped/supplied with additional outside lighting at the site?

No, the design goal is to only utilize low mast pole mounted LED fixtures around the buildings to provide the general lighting.

Can the residents look at the light layout and type to assist in the determination of suitability?

Yes, through continued coordination, the residents can review the lighting layout and fixture types proposed in the construction documents.

What are the lighting design goals?

MTA's lighting design goals are to have enough lighting in order to have safe operation of the facility and to minimize light spillover and glare to adjacent properties.

What are some of the design elements that are under consideration?

Design considerations include:

- Dark Sky compliance
- Low mast fixtures with shielding
- Targeted lighting at work stations

What is Dark Sky?

Dark Sky is a series of actions taken to prevent light pollution.

What is light pollution?

Excessive artificial light.